

DEPTH SCHEDULE							
DISTANCE						"A"	"D"
6"	WATER	OR	GAS	MAIN		4.0'	3.5'
8"	"	"	"	,,		4.3'	3.8'
10"	"	"	"	,,		4.7'	4.2'
12"	"	"	,,	"	;	5.0'	4.5'

"A" & "D" DIMENSIONS ARE SET TO ALLOW 0.6' CLEARANCE BETWEEN SEWER AND WATER LINES.

## NOTES:

- WATER MAINS AND TELEPHONE DUCTS SHALL OCCUPY ONE SIDE OF STREET; GAS MAINS AND STORM SEWERS TO OCCUPY OTHER SIDE.
- IN NEW SUBDIVISIONS, EXTEND HOUSE BRANCHES ABOUT 1' BEYOND PROPERTY LINE.
- 3. IN ALL OTHER CASES, EXTEND HOUSE BRANCHES ABOUT 1' BEYOND PROPERTY LINE OR AS DIRECTED BY CITY ENGINEER.
- REFER TO P-39A FOR LOCATION OF UNDERGROUND FACILITIES IN ARTERIAL AND COLLECTOR STREETS.
- 5. MINIMUM VERTICAL CLEARANCE BETWEEN THE HOUSE BRANCH AND WATER MAIN SHALL BE 1.0 FOOT.
- FOR TRENCH BACKFILL SEE DRWG. P-40 OR P-40A.

HOUSE BRANCH & UTILITIES LOCATIONS IN STREET

REF. & REV.

AUG. 2002

CITY OF FRESNO

S-1

<sup>\*</sup> SPECIAL APPROVAL REQUIRED FOR DEVIATION FROM 45 DEGREE STANDARD ANGLE.